

## City of Las Vegas Code and Interpretation

**AMEND:** 02

**DATE:** December 19, 2008

**CODE:**

2006 IBC <input type="checkbox"/>	2005 NEC <input type="checkbox"/>	Local Amendments <input type="checkbox"/>
2006 IRC <input type="checkbox"/>	2006 UMC <input type="checkbox"/>	POOL CODE <input type="checkbox"/>
2006 IECC <input type="checkbox"/>	2006 UPC <input type="checkbox"/>	MISC. <input checked="" type="checkbox"/> Admin Code

**CODE SECTION:** Administrative Policy and Procedure

**TOPIC:** Changes to approved plans

**PURPOSE/REASON:** When contractor does not follow specs or notes on plans is an 8 ½ X 11 letter stamped by the engineer acceptable or do the plans need to be changed by the engineer and resubmitted to plan check?

**INTERPRETATION:** We will accept an 8 ½ X 11 engineer of record wet stamped letter in the field. If the inspector is unsure or uncertain with the contents of the letter the inspector is to contact the supervisor who will make the decision if the document is to be submitted for plan review and/or plan revision.

Approved: Chris Knight, CBO